


# CONTROLLER SUBMITTAL



## RAC

## XE70-00/E1

- This controller suitable for:  
**UNIX Air Handler**



No.	①	②	③	④	⑤	⑥	⑦	⑧
Button	Fan	Set	Cancel	ON/OFF	▼	▲	System	Enter/Hold



Terminals Code	Remarks
C	24 Volt(Common)
R	24 Volt Emergency (hot)
O / B	To a AC contactor to control the 4-way valve
G	To a AC contactor to control the indoor unit fan
Y1	To a AC contactor to control compressor 1
Y2	To a AC contactor to control compressor 2
W1	To a AC contactor to control the auxiliary heater 1
W2	To a AC contactor to control the auxiliary heater 2
L	Temperature sensor error output
A	485 Communication Port(Reserved)
B	485 Communication Port(Reserved)

Note: Energization type of 4-way valve:

- “o” is applicable for the unit which operates under the cooling mode and its 4-way valve is energized;
- “b” is applicable for the unit which operates under the heating mode and its 4-way valve is energized.

Job Name:

Schedule Reference:

Date:

Specification are subject to change without notice.